F204 AC-63/0,03 IEC





F204 AC-63/0,03 IEC Residual Current Circuit Breaker

_

General Information

Extended Product Type	F204 AC-63/0,03 IEC
Product ID	2CSF204005R1630
EAN	8012542817307
Catalog Description	F204 AC-63/0,03 IEC Residual Current Circuit Breaker
Long Description	The RCCBs F200 series assures protection to people and installations against fault current to earth. This product is manufactured according to international IEC standards, for the markets where it is required.

Ordering

Minimum Order Quantity	1 piece
Customs Tariff Number	85363030

Popular Downloads

Data Sheet, Technical Information	9AKK107046A0424
Instructions and Manuals	Manual sheet inside the box

_

Dimensions

Product Net Width	0.070 m
Product Net Height	0.085 m
Product Net Depth / Length	0.069 m
Product Net Weight	0.360 kg

_

Technical

Standards	IEC 61008
Operating Characteristic	Instantaneous
Type of Residual Current	AC type
Rated Residual Current	30 mA
Rated Current (I _n)	63 A
Number of Poles	4
Position of Neutral Terminals	Right
Power Loss	at Rated Operating Conditions per Pole 4.4 W

Environmental

Ambient Air Temperature	Operation -25 +55 °C Storage -40 +70 °C
RoHS Status	Following EU Directive 2011/65/EU

_

Certificates and Declarations (Document Number)

Declaration of Conformity - CE	9AKK106713A5602
Environmental Information	Refer to RoHS
Instructions and Manuals	Manual sheet inside the box
RoHS Information	2CSC423001K2702

Container Information

Package Level 1 Units	1 piece
Package Level 1 Width	0.082 m
Package Level 1 Height	0.078 m
Package Level 1 Depth / Length	0.096 m
Package Level 1 Gross Weight	0.403 kg
Package Level 1 EAN	8012542817307

_

Classifications

Object Classification Code	Q
ETIM 4	EC000003 - Residual current circuit breaker (RCCB)
ETIM 5	EC000003 - Residual current circuit breaker (RCCB)
ETIM 6	EC000003 - Residual current circuit breaker (RCCB)
ETIM 7	EC000003 - Residual current circuit breaker (RCCB)

_

Categories

 $Low\ Voltage\ Products\ and\ Systems\ \rightarrow\ Modular\ DIN\ Rail\ Products\ \rightarrow\ Residual\ Current\ Devices\ RCDs\ \rightarrow\ Residual\ Current\ Devices\ RCDs$

